

NOTICE TO BIDDERS

Notice is hereby given that the City of Fort Stockton is accepting bids for **9 New Fire Hydrants**.

Specifications are as follows:

- Year of Manufacture: 2014-Present
- Main Valve Opening Size: 5-1/4"
- Hydrant Styles: 3-Way
- Main Valve Opening Size, 350 WP, AWWA Fire Main Hydrant, and 584 N is Cast on Barrel between Ground Line Flange and Bonnet
- Triple Listed UL/FM/AWWA (4" Shoe AWWA Only)
- Ten Year Warranty
- 350 psig Working Pressure; 700 psig Test Pressure
- High-Strength Fasteners
- Thrust Bearing in Place of a Thrust Washer
- Encapsulated Reversible Main Valve. Main Valve is easily removed from either the Bonnet Flange or Ground Line Flange
- Single Groove Traffic Flange
- The Company/Individual Awarded the bid must Complete the Installation of the Nine (9) Fire Hydrants Locally

Inquiries &/or specifications related to this bid notice may be obtained by contacting **Director of Public Works Aaron Ramos** at (432) 336-3092 or (432) 251-9676 between the hours of 8:00 a.m. – 5:00 p.m., Monday through Friday.

Sealed bid(s) shall be directed to **City Secretary Delma A. Gonzalez**, City of Fort Stockton, P.O. Box 1000 or 121 W. Second Street, Fort Stockton, Texas, 79735. **Deadline for receiving bids is 10:00 a.m., Thursday, August 23, 2018;** at which time and place they will be opened publicly and read aloud.


Approved and accepted bid will be awarded at the Regular City Council Meeting scheduled for August 28, 2018 @ 5:30 P.M.

The City Council Reserves the Right to Accept or Reject Any and/or All Bids or to Accept the Most Advantageous Bid for the City of Fort Stockton. The City of Fort Stockton is an Affirmative Action/Equal Opportunity Employer.

Bids must be sealed and marked --

“NINE (9) NEW FIRE HYDRANTS”

By order of the City Council at a Regular Meeting held on the 24th day of July, 2018.


Delma A. Gonzalez, City Secretary